

Advanced Modular 2/4-Channel PID
Temperature Controllers

TMH Series

INSTRUCTION MANUAL

TCD230056AC

Autonics

Thank you for choosing our Autonics product.

Read and understand the instruction manual and manual thoroughly before using the product.

For your safety, read and follow the below safety considerations before using.

For your safety, read and follow the considerations written in the instruction manual, other manuals and Autonics website.

Keep this instruction manual in a place where you can find easily.

The specifications, dimensions, etc are subject to change without notice for product improvement Some models may be discontinued without notice.

Follow Autonics website for the latest information.

Safety Considerations

- Observe all 'Safety Considerations' for safe and proper operation to avoid hazards.
- ⚠ symbol indicates caution due to special circumstances in which hazards may occur.

⚠ **Warning** Failure to follow instructions may result in serious injury or death

01. Fail-safe device must be installed when using the unit with machinery that may cause serious injury or substantial economic loss. (e.g. nuclear power control, medical equipment, ships, vehicles, railways, aircraft, combustion apparatus, safety equipment, crime/disaster prevention devices, etc.)
Failure to follow this instruction may result in personal injury, economic loss or fire.

02. Do not use the unit in the place where flammable/explosive/corrosive gas, humidity, direct sunlight, radiant heat, vibration, impact, or salinity may be present.
Failure to follow this instruction may result in explosion or fire.

03. Install the device in panel to use.
Failure to follow this instruction may result in fire.

04. Do not connect, repair, or inspect the unit while connected to a power source.
Failure to follow this instruction may result in fire.

05. Check 'Connections' before wiring.
Failure to follow this instruction may result in fire.

06. Do not disassemble or modify the unit.
Failure to follow this instruction may result in fire.

⚠ **Caution** Failure to follow instructions may result in injury or product damage

01. When connecting the power input and relay output, use AWG 20 (0.50 mm²) cable or over and tighten the terminal screw with a tightening torque of 0.74 to 0.90 N·m for screw type.
When connecting the sensor input and communication cable without dedicated cable, use AWG 24 to 12 cable for screwless type , use AWG 28 to 16 cable for screw type, and tighten the terminal screw with a tightening torque of 0.74 to 0.90 N·m for screw type.
Failure to follow this instruction may result in fire or malfunction due to contact failure.

02. Use the unit within the rated specifications.
Failure to follow this instruction may result in fire or product damage

03. Use a dry cloth to clean the unit, and do not use water or organic solvent.
Failure to follow this instruction may result in fire or electric shock.

04. Keep the product away from metal chip, dust, and wire residue which flow into the unit.
Failure to follow this instruction may result in fire or product damage.

Cautions during Use

- Follow instructions in 'Cautions during Use'. Otherwise, it may cause unexpected accidents.
- Check the polarity of the terminals before wiring the temperature sensor.
For RTD temperature sensor, wire it as 3-wire type, using cables in same thickness and length.
For thermocouple (CT) temperature sensor, use the designated compensation wire for extending wire.
- The connection of this unit should be separated from the power line and high voltage line in order to prevent inductive noise.
In case of installing power line and input signal line closely, use line filter or varistor at power line and shielded wire at input signal line.
The connection of this unit should be separated from the power line and high voltage line in order to prevent inductive noise.
- Do not apply excessive power when connecting or disconnecting the connectors of the product.
- Switch or circuit breaker should be installed nearby users for convenient control.
- Do not use the unit for other purpose (e.g. voltmeter, ammeter), but temperature controller.

- When changing the input sensor, turn off the power first before changing.
After changing the input sensor, modify the value of the corresponding parameter.
- Power supply should be insulated and limited voltage/current or Class 2, SELV power supply device.
- Do not overlapping communication line and power line.
Use twisted pair wire for communication line and connect ferrite bead at each end of line to reduce the effect of external noise.
- Make a required space around the unit for radiation of heat.
For accurate temperature measurement, warm up the unit over 20 min after turning on the power.
- Mounting multiple devices in any way other than the specified mounting method may cause heat to build up inside, which will shorten their service life. If there is a possibility of the ambient temperature rising to a temperature above the specified temperature range, take steps, such as installing fans, to cool the device. Be sure that the cooling method in not cooling just the terminal block. If only the terminal block is cooled, measurement errors may occur.
- Make sure that power supply voltage reaches to the rated voltage within 2 sec after supplying power.
- Do not wire to terminals which are not used.
- Install DIN rail vertically from the ground.
- This unit may be used in the following environments.
 - Indoors (in the environment condition rated in 'Specifications')
 - Altitude max 2,000 m
 - Pollution degree 2
 - Installation category II

Ordering Information

This is only for reference, the actual product does not support all combinations.
For selecting the specified model, follow the Autonics website.

Control module

T	M	H	①	-	②	③	④	-	⑤
---	---	---	---	---	---	---	---	---	---

① Module

2: Control 2 channels
4: Control 4 channels

② Option Input/Output

2: Alarm output 1/2 (Module: 2)
4: Alarm output 1/2/3/4 (Module: 2)
N: None (Module: 4)

③ Power supply

2: 24 VDC

④ Control output

R: Relay output
S: SSR drive output
C: Selectable current or SSR drive output

⑤ Terminal type

None: Screw
L: Screwless

Option module

T	M	H	①	-	②	③	④	-	⑤
---	---	---	---	---	---	---	---	---	---

① Module

A: Analog input/output
E: Digital input/Alarm output
CT: CT input

② Option Input/Output

4: Analog 1 to 4 (Module: A)
8: Digital input 1 to 8, Alarm output 1 to 8 (Module: E)
8: CT input 1 to 8 (Module: CT)

③ Power supply

2: 24 VDC

④ Output

A: Transmission output
R: Relay output
N: None

⑤ Terminal type

None: Screw
L: Screwless

Communication module

T	M	H	①	-	②	③	④	-	⑤
---	---	---	---	---	---	---	---	---	---

① Module

C: Communication

② Option Input/Output

2: Communication output COM1+ COM2

③ Power supply

2: 24 VDC

④ Communication

E: Ethernet
L: PLC Ladderless

⑤ Terminal type

None: Screw
L: Screwless

Firmware Version and Manual

Additional settings may be required if the firmware version is different between the connected modules.
Please refer to the user manual and the user manual for communication, and be sure to follow cautions written in the technical descriptions.
Visit our website (www.autonics.com) to download manuals.

Software

Download the installation file and the manuals from the Autonics website.

DAQMaster

DAQMaster is comprehensive device management program. It is available for parameter setting, monitoring.

Product Components

- Product (+ bracket)
- Expansion connector × 1
- [Screwless type] 5-pin connector × 4

- Instruction manual
- Module lock connector × 2

Sold Separately

- Current transformer (CT)
- Communication Converters: SCM-USP / SCM-38I / SCM-US48I / SCM-WF48
- CT connector cable: CICT4-□
- Terminal Protection Cover: TMH-COVER

Specifications

Control module

Model	TMH2-□□□□	TMH2-□□□□-L	TMH4-□□□□	TMH4-□□□□-L
No. of channels	2 channels		4 channels	
Sampling period	50 ms (2 channels or 4 channels synchronous sampling)			
Input specification	Thermocouple, RTD, Analog (refer to 'Input Specification')			
CT input	• 0.0 - 50.0A (primary current measurement range) • CT ratio: 1/1,000, • Measurement accuracy: ±5% F.S. ±1 digit			
Digital input	• Connect input ON: ≤ 1 kΩ, OFF: ≥ 100 kΩ • Solid state input Residual voltage: ≤ 0.9 V, Leakage current: ≤ 0.5 mA • Outflow current: ≈ 0.3 mA per input		-	
Control type	Heating, cooling, heating & cooling: ON/OFF, P, PI, PD, PID control			
Control output	• Relay: 250 VAC ~ 3 A 1a mechanical life cycle: ≥ 10,000,000 operations, electrical life cycle: ≥ 100,000 operations • SSR: 12 VDC = ± 3 V, ≤ 20 mA • Current ⁰¹⁾ : DC 4 - 20 mA or DC 0 - 20 mA (Load: ≤ 500 Ω)			
Alarm output	250 VAC ~ 3 A 1a Mechanical life cycle: ≥ 10,000,000 operations Electrical life cycle: ≥ 100,000 operations		-	
Communication	Modbus RTU			
Hysteresis	• Thermocouple / RTD: 1 to 100 (0.1 to 100.0) °C/°F • Analog: 1 to 100 digit			
Proportional band (P)	• Thermocouple / RTD: 0.1 to 999.9 °C/°F • Analog: 0.1 to 999.9 %			
Integral time (I)	0 to 9,999 sec			
Derivative time (D)	0 to 9,999 sec			
Control period (T)	• Relay output, SSR drive output: 0.1 to 120.0 sec • Selectable current or SSR drive output: 1.0 to 120.0 sec			
Manual reset	0 to 100 (0.0 to 100.0) %			
Insulation type	Double insulation or reinforced insulation (mark: □, dielectric strength between the measuring input part and the power part: 1 kV)			
Unit weight (packaged)	≈ 174 g (≈ 249 g)	≈ 162 g (≈ 261 g)	≈ 154 g (≈ 229 g)	≈ 151 g (≈ 250 g)

01) When the control output is set to the current output, the heater current value monitoring function through the CT input terminals is not available.

Option module

Model	TMHA-42A	TMHA-42A-L
No. of channels	4 channels	
Sampling period	50 ms (4 channels synchronous sampling)	
Input specification	Thermocouple, RTD, analog (refer to 'Input Specification')	
Transmission output	DC 4 - 20 mA or DC 0 - 20 mA (Load: ≤ 500 Ω)	
Communication	Modbus RTU	
Insulation type	Double insulation or reinforced insulation (mark: □, dielectric strength between the measuring input part and the power part: 1 kV)	
Unit weight (packaged)	≈ 160 g (≈ 235 g)	≈ 148 g (≈ 247 g)

Model

Model	TMHE-82R	TMHE-82R-L	TMHCT-82N	TMHCT-82N-L
No. of I/O points	8 points		8 points	
Input specification	- Digital input • Connect input ON: ≤ 1 kΩ, OFF: ≥ 100 kΩ • Solid state input Residual voltage: ≤ 0.9 V, Leakage current: ≤ 0.5 mA • Outflow current: ≈ 0.3 mA per input		- CT input • 0.0-50.0 A (primary current measurement range) • CT ratio: 1/1,000 • Measurement accuracy: ±5% F.S. ±1 digit	
Alarm output	250 VAC ~ 3 A 1a, • Mechanical life cycle: ≤ 10,000,000 operations • Electrical life cycle: ≤ 100,000 operations		-	
Communication	Modbus RTU			
Insulation type	Double insulation or reinforced insulation (mark: □, dielectric strength between the measuring input part and the power part: 1 kV)		-	
Unit weight (packaged)	≈ 163 g (≈ 239 g)	≈ 151 g (≈ 250 g)	≈ 144 g (≈ 219 g)	≈ 133 g (≈ 232 g)

Communication module

Model	TMHC-22L	TMHC-22L-L	TMHC-22E
Communi-cation	COM1 COM2	• Connection type: RS422 / RS485 • Protocol: Modbus RTU, PLC Ladderless communication	• Connection type: Ethernet (10/100BaseT) • Protocol: Modbus TCP
Insulation type	Double insulation or reinforced insulation (mark: □, dielectric strength between the measuring input part and the power part: 1 kV)		
Unit weight (packaged)	≈ 147 g (≈ 222 g)	≈ 137 g (≈ 236 g)	≈ 129 g (≈ 204 g)

Common	
Power supply	24 VDC =
Permissible voltage range	90 to 110% of rated voltage
Power Consumption	≤ 5 W (for max. load)
Display type	None- parameter setting and monitoring is available at external devices
Memory retention	≈ 10 years (non-volatile semiconductor memory type)
Insulation resistance	100 MΩ (500 VDC = megger)
Dielectric strength	Between the charging part and the case: 1,000 VAC ~ 50/60 Hz for 1 min
Vibration	0.75mm amplitude at frequency of 5 to 55Hz in each X, Y, Z direction for 2 hours
Noise immunity	Square shaped noise by noise simulator (pulse width 1 μs) ±0.5 kV
Ambient temperature	-10 to 50 °C, storage: -20 to 60 °C (no freezing or condensation)
Ambient humidity	35 to 85%RH, Storage: 35 to 85%RH (no freezing or condensation)
Protection structure	IP20 (IEC standard)
Certification	CE, RoHS, REACH

Input Specifications					
Input type and range					
The setting range of some parameters is limited when using the decimal point display.					
Input type		Decimal point	Display Method	Input range (°C)	Input range (°F)
Thermo-couple	K (CA)	1	K (CA) .H	-200 to 1,350	-328 to 2,462
		0.1	K (CA) .L	-200.0 to 1,350.0	-328.0 to 2,462.0
	J (IC)	1	J (IC) .H	-200 to 800	-328 to 1,472
		0.1	J (IC) .L	-200.0 to 800.0	-328.0 to 1,472.0
	E (CR)	1	E (CR) .H	-200 to 800	-328 to 1,472
		0.1	E (CR) .L	-200.0 to 800.0	-328.0 to 1,472.0
	T (CC)	1	T (CC) .H	-200 to 400	-328 to 752
		0.1	T (CC) .L	-200.0 to 400.0	-328.0 to 752.0
	B (PR)	1	B (PR)	0 to 1,800	32 to 3,272
	R (PR)	1	R (PR)	0 to 1,750	32 to 3,182
	S (PR)	1	S (PR)	0 to 1,750	32 to 3,182
	N (NN)	1	N (NN)	-200 to 1,300	-328 to 2,372
	C (TT)	1	C (TT)	0 to 2,300	32 to 4,172
	G (TT)	1	G (TT)	0 to 2,300	32 to 4,172
	L (IC)	1	L (IC) .H	-200 to 900	-328 to 1,652
		0.1	L (IC) .L	-200.0 to 900.0	-328.0 to 1,652.0
RTD	U (CC)	1	U (CC) .H	-200 to 400	-328 to 752
		0.1	U (CC) .L	-200.0 to 400.0	-328.0 to 752.0
	Platinel II	1	PLII	0 to 1,390	32 to 2,534
	Cu50 Ω	0.1	CU 50	-200.0 to 200.0	-328.0 to 392.0
	Cu100 Ω	0.1	CU 100	-200.0 to 200.0	-328.0 to 392.0
	JPt100 Ω	1	JPt100.H	-200 to 650	-328 to 1,202
		0.1	JPt100.L	-200.0 to 650.0	-328.0 to 1,202.0
	DPT50 Ω	0.1	DPT50.L	-200.0 to 600.0	-328.0 to 1,112.0
		1	DPT100.H	-200 to 650	-328 to 1,202
	DPT100 Ω	0.1	DPT100.L	-200.0 to 650.0	-328.0 to 1,202.0
Analog	Nickel120 Ω	1	NI12	-80 to 260	-112 to 500
	0 to 10 V	-	AV1		0 ~ 10 V
	0 to 5 V	-	AV2		0 ~ 5 V
	1 to 5 V	-	AV3		1 ~ 5 V
	0 to 100 mV	-	AMV1		0 ~ 100 mV
	0 to 20 mA	-	AMA1		0 ~ 20 mA
	4 to 20 mA	-	AMA2		4 ~ 20 mA
• Permissible line resistance per line: ≤ 5 Ω					

Measurement accuracy			
Input type	Using temperature	Terimal type	Measurement accuracy
Thermo-couple	At room temperature (23 ± 5 °C)	Screw	(PV ±0.3% or ±1 °C higher one) ±1-digit • Thermocouple K, J, T, N, E below -100 °C and L, U, PLII, RTD Cu50 Ω, DPT50 Ω: (PV ±0.3% or ±2 °C higher one) ±1-digit • Thermocouple C, G and R, S below 200 °C: (PV ±0.3% or ±3 °C higher one) ±1-digit • Thermocouple B below 400°C: there is no accuracy standards
		Screwless	(PV ±0.5% or ±1 °C higher one) ±1-digit • Thermocouple K, J, T, N, E below -100 °C and L, U, PLII, RTD Cu50 Ω, DPT50 Ω: (PV ±0.5% or ±2 °C higher one) ±1-digit • Thermocouple C, G and R, S below 200 °C: (PV ±0.5% or ±3 °C higher one) ±1-digit • Thermocouple B below 400°C: there is no accuracy standards
	Out of room temperature range		(PV ±0.5% or ±2 °C higher one) ±1-digit • RTD Cu50 Ω, DPT50 Ω: (PV ±0.5% or ±3 °C higher one) ±1-digit • Thermocouple R, S, B, C, G: (PV ±0.5% or ±5 °C higher one) ±1-digit • Other sensors: ≤ ±5 °C (≤-100 °C)
Analog	At room temperature (23 ± 5 °C)		±0.3% F.S. ±1-digit
	Out of room temperature range		±0.5% F.S. ±1-digit




• Connecting 1 or more module can vary measurement accuracy about ±1°C, regardless of the number of connected module.

Communication Setting				
■ Interface				
Module	Control	Option	Communication	
Series	TMH2/4	TMHA, TMHE, TMHCT	TMHC-22L	TMHC-22E
Protocol	Modbus RTU		Modbus RTU, PLC Ladderless communication	Modbus TCP
Comm. method	RS485		RS422, RS485	Ethernet (10/100BaseT)
PC loader	TTL (Protocol: Modbus RTU)			
Maximum connection	32 units (address: 01 to 32) • 16 units in case of connecting TMHC module (address: 01 to 16)	16 units per each module	Control module 16 units, option module 16 units per each module (32 units in total)	
Synchronization	Asynchronous			
Connection method	Two-wire half duplex			
Comm. effective range	≤ 800 m			
Comm. speed	4,800 / 9,600 (default) / 19,200 / 38,400 / 115,200 bps (parameter)			10/100 Mbps
Response time	5 to 99 ms (default: 20 ms)			
Start bit	1 bit (fixed)			
Data bit	8 bit (fixed)			
Parity bit	None (default) , Odd, Even			
Stop bit	1 bit, 2 bit (default)			
EEPROM life cycle	≈ 1,000,000 operations (Erase / Write)			

- When changing the setting value related to communication interface, reboot the device for normal operation.
- It is recommended to use Autonics communication converter. Please use twisted pair wire, which is suitable for RS485 communication.

■ Address

Set the communication address with the communication address setting switch (SW1, default: 1) and communication address group switch (SW2, default: +0, TMH2/4 Series).

SW1																	
		0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
Series		16	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
		32	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31
TMH2/4		16	01	02	03	04	05	06	07	08	09	10	11	12	13	14	15
TMHC		48	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47
TMHA		64	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63
TMHE		80	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79
TMHCT																	

- When connecting TMHC and TMH2/4 to master separately, communication address can be duplicated, but if they communicate with master at the same time, communication address must not be duplicated to avoid error. (use address TMHC: 1 to 16, TMH2/4: 17 to 32)


■ Mac address [Ethernet communication module]

It is possible to check Mac address for Ethernet communication at DAQMaster. Refer to the manual for the details.

■ DIP switch setting [Ladderless communication module]

After separating base terminal block, set communication speed, stop bit, PLC connection and protocol by using a internal DIP switch.

- Setting values are applied to COM1 only, default: All switches OFF (following parameter setting)



DIP SW1					
1	2	Communication speed	3	4	Stop bit
OFF	OFF	Following parameter setting	OFF	OFF	Following parameter setting
OFF	ON	19,200 bps	OFF	ON	Stop bit: 1 bit
ON	OFF	38,400 bps	ON	OFF	Stop bit: 2 bit
ON	ON	115,200 bps	ON	ON	-

DIP SW2		3	4	PLC connection and protocol
OFF	OFF	OFF	OFF	Following parameter setting
OFF	OFF	OFF	ON	Modbus RTU
OFF	OFF	ON	OFF	LS MASTER-K Series special protocol
OFF	OFF	ON	ON	LS GLOFA-GM Series special protocol
OFF	ON	OFF	OFF	LS XGT/XGB Series special protocol
OFF	ON	OFF	ON	MITSUBISHI MELSEC Series special protocol Q/QnACPU common command (1401/0401)
OFF	ON	ON	OFF	MITSUBISHI MELSEC Series special protocol ACPU common command (WW/WR)
OFF	ON	ON	ON	OMRON SYSMAC Series special protocol
ON	OFF	OFF	OFF	MITSUBISHI MELSEC3 Series special protocol

Installation Method

■ Separating base terminal block

- When connecting base terminal block, align the upper concave part (凹) of the body and the upper convex part (凸) of the base, then lower it vertically to connect it. If the upper parts are not align correctly, it may damage to the inner connector.

■ Connection between modules

- Supply power to the rear power terminal of only one of the connected modules. Supply adequate power for power input specifications and overall capacity. (Max. power when connecting 32 modules: 32 × 5 W = 160 W)

■ Mounting with bolts

■ Mounting on DIN rail

- Installation


- Separation

■ Precautions

- Install the module vertically.
- Use end plates (sold separately, not available from Autonics) to fix firmly.

Dimensions

- Unit: mm, For the detailed drawings, follow the Autonics website.





Terminal

- Unit: mm, Use the terminal of follow shape.

■ Screw: Crimp terminal





■ Screwless: Wire ferrule

Connections



CT connector cable

Pin	Cable color	CT connection
1	Brown	CT 2 / 4
2	Blue	CT 2 / 4
3	White	CT 1 / 3
4	Black	CT 1 / 3



Errors

■ Indicator				
Name	Status	Color	Description	Troubleshooting
PWR	ON	Red	□ channel error: Input < Input range, Input > Input range, Input sensor is open or not connected	When the error factor is resolved, it automatically returns to normal operation.
CH□	Flash ⁰¹⁾	Red		

01) Cycle: 0.5 sec

■ Communication output, DAQMaster			
Communication output (decimal)	DAQMaster	Description	Troubleshooting
'31000'	Display 'OPEN'	Input sensor is open or not connected	When the error factor is resolved, it automatically returns to normal operation.
'30000'	Display 'HHHH' ⁰¹⁾	Input > Input range	
'-30000'	Display 'LLLL' ⁰¹⁾	Input < Input range	
'31500'	Display '31500'	Sensor internal communication error	Check the power supply (24VDC≒). ⁰²⁾

01) When HHHH / LLLL error occurs, the control output may occur by recognizing the maximum or minimum input depending on the control type. Please be careful.
02) This error may occur when connecting only the loader port.